Installation Guide - GreaseShield®2000-F



- 1 GS2000 Unit: Ensure that there is sufficient clearance above and to the right of the unit for servicing purposes (5.9"/150mm minimum).
- 2 Inlet Pipe 1½2"/40mm: To be piped with a sufficient fall of no less than 1 in 40.
- 3 Outlet Pipe 2"/54mm: To be piped with a sufficient fall of no less than 1 in 40.
- 4 Decant Outlet Hose 3/4"/18mm: To be piped directly into the main drainage pipe via a vented drainage stack as shown. The Hose must be fixed in place using the drainage hose support provided.
- 5 FilterShield2000™: Ensure sufficient height above the FilterShield™2000 to allow for removal and daily maintenance of FilterShield™2000 basket. Be sure to remove the plastic knock-out for the selected FilterShield™2000 Outlet.
- 6 FilterShield™2000 Inlet 11/2"/40mm: To be piped with a sufficient fall of no less than 1 in 40.
- 7 Alternate FilterShield™2000 Outlet 1½"/40mm: Must be capped off with the 1½"/40mm FlexiPlumb Endcap provided. Or alternatively make sure the plastic knock-out is still securely in place.
- 6 FilterShield™2000 Basket: A FilterShield™2000 basket must be installed into the FilterShield™2000 at all times.
- 9 FilterShield™2000 Lid: The FilterShield™2000 Lid must be in place during normal operation and should only be removed for daily maintenance.
- FilterShield™2000 Hygiene Stand (Optional Extra): The FilterShield™2000 should be secured to a Stainless Steel FilterShield™2000 Hygiene Stand, which provides easy access for daily maintenance.
- 🛂 Sampling Point: Connected to the outlet of the unit: it is essential in the analysis of effluent leaving the unit.
- 😰 Running Trap: The outlet of unit must be fitted with a running trap to reduce foul smells.
- 13 FOG Container: Ensure that the container is not restricted or blocked for daily maintenance.
- Hot Water Solenoid Valve: Hot water must be connected to the unit using the 3/4" BSP (F/F) Red PVC Hose provided, water supply must not exceed 3 bar pressure and 60°C/140°F. In the case of high pressure a pressure reducing valve must be used. Mains water connections must be made via a WRAS approved isolation valve which follows a WRAS approved double check valve.
- 15 Power Lead: The unit must be plugged into a 13 amp rated IP56 socket located below counter level.
- 16 Interconnecting Pipework: All pipework must be clipped and properly supported.
- Stainless Steel Hygiene Stand (Optional Extra): GS2000 unit should be installed on a Stainless Steel Hygiene stand. It can be adjusted up to 2"/50mm in height to allow the unit to be levelled on uneven surfaces and provide access for cleaning.



V9 05/07/2021

sales@epas-ltd.com

Installation Guide - GreaseShield®2000-F





- Make sure the unit is installed on level ground or adjust the stand feet to ensure the unit is level.
- Have a hot water connection available to connect to the unit, if one is not available the unit must be equipped with a Genie H2O to give hot water on demand. Water connection must be made via a WRAS approved isolation valve A and double check valve B.
- Have an IP56 rated socket Cbelow counter level available to the unit to plug into. If a genie H2O is required ensure an additional power supply (preferably a fuse spur) is available.
- Ensure all pipe work into and out of the unit has at least a 1 in 40 fall (downwards angle of 1.5°).
- Clean the FilterShield™ basket and FOG container daily.
- An Air Admittance Valve must be installed after the running trap so a siphon doesn't occur.
 The Decant Outlet Hose eneeds to be plumbed into a vented drainage stack, using the drain hose support provided.



- Place the unit in passageways where it can be a hazard or be damaged.
 Open the unit or insert hands into any part of the unit; moving parts can cause injury.
- Stand or place heavy objects on top of the unit.
- **DON'T** Dismantle the unit in any way, only qualified service staff are to access the inside of the unit.



V9 05/07/2021